

# SAR-GEL® Water Indicating Paste

Catalog Number: 24615

## DESCRIPTION

Water indicating paste provides a fast, reliable way to detect water phase separation in storage tanks containing gasoline and gasoline/alcohol blends, diesel, jet fuel, fuel oil, solvents and other materials.

## PROCEDURE

1. Apply a small amount of SAR-GEL® paste to the end of a gauge stick.
2. Spread the paste over a few inches on the surface of the gauge stick.
3. Insert the gauge stick into the reservoir for recommended time (listed in table below).
4. The presence of water is indicated when the SAR-GEL® paste turns to a navy blue color.

## ADVANTAGES

- Easy to apply – no messy jars, no need to mix
- No guessing – complete color change from orange to navy blue
- Easier to see water line – does not run
- Fast easy clean-up

**Table 1- Guideline for gauge to be in reservoir of fluid**

Fluid	Detection Time
Gasoline with Alcohol	Approx. 5 seconds
Fuel Oil	Approx. 5 seconds
Biodiesel	Approx. 5 seconds
Diesel	Approx. 5 seconds
Hydrocarbons	Approx. 5 seconds
E10	Approx. 90 seconds
E15	Approx. 90 seconds
E20	Approx. 90 seconds

## ORDERING INFORMATION

Cat. #	Description	Size
24615-12	SAR-GEL® Water Indicating Paste	12x1 oz tubes

Visit [Polysciences.com](https://www.polysciences.com) any time to place an order.